



Via Vicenza 45
31050 VEDELAGO (TV)
Tel 0423 400621
Fax 0423 401177

**CERTIFICATE OF CONFORMITY: COPPER TUBE
COATED WITH CROSS LINKED PE FOAM**

In accordo con: EN 10204 -2.2

CUSTOMER

SIA KLIMATKONTROLE

ITEM CODE

2RGIGGRL#GF100A

COPPER TUBE

NOMINAL DIMENSION [mm]		3/4" x 1,00 mm	
NORM		EN 12735-1 / CUSTOMER TECHNICAL SPECIFICATIONS	
ITEM NAME		GREEN	
CHEMICAL COMPOSITION		CU-DHP	
PHYSICAL STATE		ANNEALED	
TENSILE STRENGTH	[MPa]	> 220	
ELOGANTION	[%]	> 40	
MARKING	FEINROHREN ITALIA CU-DHP ANNO TRIM		

**CROSS LINKED
PE FOAM**

Propriety	Norm	Required	Result
DENSITY [Kg/m³]	ISO 845	30	OK
THICKNESS [mm]		9	OK
WATER VAPOR DIFFUSION RESISTANCE [μ]	EN 12086:2013	>9000	OK
THERMAL CONDUCTIVITY AT 0°-40°C [W/m K]	EN 12667:2001	0,0377<math>\lambda</math><0,0435	OK
MARKING	<Mt. 99> "IMPERIALE GEL" 3/4 X 1 EN 12735-1 Euroclass Bs2d0 EN 13501-1 <logo CE> R410A-R32 <linea - data>		

**THIS DOCUMENT CERTIFIES THAT THE PRODUCT COMPLIES WITH
AGREED SPECIFICATIONS**