



Via Vicenza 45
31050 VEDELAGO (TV)
Tel 0423 400621
Fax 0423 401177

CERTIFICATE OF CONFORMITY: COPPER TUBE COATED WITH CROSS LINKED PE FOAM

In accordo con: EN 10204 -2.2

CUSTOMER

SIA KLIMATKONTROLE

ITEM CODE

2RGIGGRL#GC075A

COPPER TUBE

NOMINAL DIMENSION [mm]

3/8" x 0,80 mm

NORM

EN 12735-1 / CUSTOMER TECHNICAL
SPECIFICATIONS

ITEM NAME

GREEN

CHEMICAL COMPOSITION

CU-DHP

PHYSICAL STATE

ANNEALED

TENSILE STRENGTH

[MPa]

> 220

ELOGANTION

[%]

> 40

MARKING

FEINROHREN ITALIA CU-DHP ANNO TRIM

CROSS LINKED PE FOAM

Propriety

Norm

Required

Result

DENSITY [Kg/m³]

ISO 845

30

OK

THICKNESS [mm]

7

OK

WATER VAPOR DIFFUSION
RESISTANCE [μ]

EN
12086:2013

>9000

OK

THERMAL CONDUCTIVITY
AT 0°-40°C [W/m K]

EN
12667:2001

0,0377< λ <0,0435

OK

MARKING

<Mt. 99> "IMPERIALE GEL" 3/8 X 0,8 EN 12735-1
Euroclass Bs2d0 EN 13501-1 <logo CE> R410A-R32
<linea - data>

**THIS DOCUMENT CERTIFIES THAT THE PRODUCT COMPLIES WITH
AGREED SPECIFICATIONS**